



Top View



Front View



Side View

Transformer Name Plate Data

Serial # : 120620	Type: DNAN	Built: 1984
Make:Woden	H.V.: 27600V	Z%: 5,61
KVA: 3000	Temp.Rise:65 C	L.V.: 600Y/347V
Vector Rel.: D/Y	Tx.Wt.: 15635 lbs	Dwg.#: CS4777
Gals. Oil: 550	BILLV: 30kV	
BILHV :170kV		

Tap Position	Voltage	Amperes
1	28,980	59.8
2	28,290	61.2
3	27,600	62.8
4	26,910	64.4
5	26,220	66.0

Identification

1. Transformer Main Tank
2. Transformer cooling fins
3. Secondary Junction Box
4. Main Sample Valve
5. H.V. Bushings
6. Pressure Relief Device
7. Pressure/Vac. Gauge
8. Liquid Level Gauge
9. Temperature Gauge
10. Tap Changer

LTL	
LINEMAN'S TESTING LABORATORIES	
41 RIVALDA ROAD, WESTON, ONTARIO M9M 2M8 Tel: (416) 742-6911-2 Fax: (416) 748-0290	
Project 3000KVA Transformer	Title Detail and Data
By: GM	Approv:
	Scale: NTS